

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Additional Information on page 2  
AC 230/400 V; B 6 - 63 A; C 0,5 - 63 A;  
Number of poles: 1; 2; 3; 4  
Instantaneous tripping current B; C

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Serie(s) S 200 M UC

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015  
IEC 60898-1:2015/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

299382-TL3-000 to -039

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2023-02-27

Signature:

T. Stenger