

# Environmental Monitoring Report - Moorebank



|  |  |
|--|--|
| Licensee Name  | ABB Australia Pty Ltd  |
| Address  | Bapaume Rd, Moorebank NSW 2170   |
| EPA License Number                                   | <a href="#">20002</a>  |
| Month (sampling period)                              | March  |
| Year   | 2017   |
| Reported by  | B.Alexander  |
| Data logging location(s)                             | SF6 recycling plant  |
| Monitoring frequency                                 | Monitoring during processing and handling of SF6, no other frequency requirement defined by license. |
| Monitoring response time                             | < 1 minute per channel, there are 4 channels   |
| Discharge limits imposed by license                  | 0 ppm  |
| SF6 discharged                                       | 0 ppm  |
| SF6 discharged (YTD)                                 | 0 ppm  |
| Date of data obtained                                | 4/4/17   |
| If discharge was recorded, what caused the discharge | No discharge recorded this month   |
| If discharge was recorded, what action was taken     | No discharge recorded this month   |
| Date of the data published                           | 4/4/17   |