

THURSDAY, JUNE 27, 2024

IEC61850, Ethernet Redundancy and Digital Substation journey

Introduction and Application

Harlem Tsai, ASM – South Asia Region



IEC61850, Ethernet Redundancy and Digital Substation Journey

- Introduction
- IEC 61850 Standard Scope
- Data Modeling Approach
- Communication Services in Substation
- GOOSE and Sample Values
- Engineering
- Conformance Testing
- Ethernet Redundancy
- Digital Substation Journey
- Summary
- Questions and Answers

IEC61850, Ethernet Redundancy and Digital Substation Journey

- Introduction
- IEC 61850 Standard Scope
- Data Modeling Approach
- Communication Services in Substation
- GOOSE and Sample Values
- Engineering
- Conformance Testing

IEC61850, Ethernet Redundancy and Digital Substation Journey

Much more than a protocol




- Modularization and structuring of data
- On-line information
- Free allocation of functions in IEDs
- Complete description of configuration
- Structured engineering and services
- Testing, validation and certification

Standardizing of function/equipment, data attributes & location within the system

IEC61850, Ethernet Redundancy and Digital Substation Journey

Why IEC 61850 is unique?



IEC61850, Ethernet Redundancy and Digital Substation Journey

IEC 61850 standard scope

WHAT?

What is Communicated?

Data Model

“Vocabulary”, “Words” of the communication

HOW?

How it is Communicated?

Communication Services

“Grammar”, “Structure” of the communication

BY WHAT?

By What is Communicated?

Mapping (Protocols)

“Channel”, “Medium” of the communication

ENGINEERING

Definition of the communication between configuration of tools of different vendors

SCL (System Configuration Language)

TESTING

To ensure interoperability,


Conformance/Performance/Functional Testing

IEC61850, Ethernet Redundancy and Digital Substation Journey

Structure of IEC 61850

Legend

- System aspects
- Configuration definition
- Data models and Basic communication structure
- Mapping to real Communication Networks
- Testing



IEC61850, Ethernet Redundancy and Digital Substation Journey

Latest parts of IEC 61850

Part 1: Introduction & overview

Part 2: Glossary

Part 3: General requirements

Part 4: System & project management

Part 5: Communication requirements for functions & device models

Part 6: Configuration description language for communication in electrical substations related to IEDs

Part 7-1: Basic communication structure – Principles & models

Part 7-2: Basic communication structure – Abstract communication service interface (ACSI)

Part 7-3: Basic communication structure – Common data classes

Part 7-4: Basic communication structure – Compatible logical node classes & data classes

Part 7-410: Hydroelectric power plants – Communication for monitoring & control

Part 7-420: Basic communication structure – Distributed energy resources logical nodes

Part 7-5: IEC 61850 – Modelling concepts¹

Part 7-500: Use of logical nodes to model functions of a substation automation system¹

Part 7-510: Use of logical nodes to model functions of a hydro power plant

Part 7-520: Use of logical nodes to model functions of distributed energy resources¹

Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO 9506-1 & ISO 9506-2) & to ISO/IEC 8802-3

Part 80-1: Guideline to exchange information from a CDC based data model using IEC 60870-5-101/104

Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3

Part 90-1: Use of IEC 61850 for the communication between substations

Part 90-2: Using IEC 61850 for the communication between substations & control centres¹

Part 90-3: Using IEC 61850 for condition monitoring¹

Part 90-4: Network Engineering Guidelines - Technical report¹

Part 90-5: Using IEC 61850 to transmit synchrophasor information according to IEEE C37.118

Part 10: Conformance testing

IEC61850, Ethernet Redundancy and Digital Substation Journey

Edition 1 and 2 differences in general

Edition 1


- The first parts of the standard SERIES IEC 61850 have been published between 2001 & 2004.
- These standards was foreseen for **Substation automation only**

Edition 2

- More **primary equipment to be modelled**, hierarchical modeling functions, e.g. bay protection / distance protection / protection zone / impedance protection
- **Broadens the application** space of the base standard (Substation automation) to further application areas.
- Added more details & more options for the available communication **redundancy protocols**, available client services, limits of data flow engineering
- Allowing a more fitting IED selection as well as a more secure IED system engineering by a system tool

IEC61850, Ethernet Redundancy and Digital Substation Journey


Communication stacks and mapping used in IEC 61850




- The standard defines an XML description language for substation automation systems.
- The language facilitates efficient integration of devices into systems in an automated fashion.
- Additionally the standard supports a comprehensive & consistent system definition & engineering, which makes not only the devices, but also their tools & systems interoperable

IEC 61850 and Ethernet Redundancy


Data modeling approach



Real World Device




Circuit Breaker



IEC61850, Ethernet Redundancy and Digital Substation Journey

Data modeling approach contd.



IEC61850, Ethernet Redundancy and Digital Substation Journey

Data modeling approach example


CTRL.ESSXSWI1.Pos.stVal

IED:	LD:	LN:	DObject:	DAttr:	FC:
REF615_5 (LD0)	CTRL	ESSXSWI1	Pos	stVal [ST]	ST
	CTRL	DCSXSWI1	OpDITmms	ctlModel [CF]	stVal
	DR	DCSXSWI2	Pos	q [ST]	
	LD0	DCSXSWI3	PosCls	stVal [ST]	
		ESSXSWI1	PosOk	t [ST]	
		LLN0	PosOpn		
		LPHD1	SwOpCap		

- Logical Device represents a function group
- Logical Node contains separate function
- Data Object specifies a part of information provided by function
- Data Attribute keeps a particular value

IEC61850, Ethernet Redundancy and Digital Substation Journey

Communication services in substation



- Thanks to IEC 61850-8-1 part which allows the elimination of copper wires between relays on horizontal level i.e. relay-to-relay communications - **substation bus** & IEC 61850-9-2LE which allows sharing of digitized information from instrument transformers or sensors in a standardized way to other relays- **process bus**. These services are classified as:

Client-Server Service:

- MMS traffic** defined in IEC 61850-8-1, which allows an MMS client such as the SCADA, an OPC server or a gateway to access “vertically” all IED objects. This traffic flows both on the station bus & on the process bus.

Real Time Service:

- GOOSE traffic** defined in IEC 61850-8-1, which allows IEDs to exchange data “horizontally” between the bays or “vertically” between process level & bay level, especially for the status signals & tripping signals, & often for interlocking. This traffic flows normally over the station bus and/or the process bus.
- SV (Sample Value) traffic** defined in IEC 61850-9-2, which carries voltage and current samples. This traffic flows normally on the process bus but can also flow over the station bus, for instance, for busbar protection, centralized protection & control & phasor measurement.


IEC61850, Ethernet Redundancy and Digital Substation Journey

Key difference between various services

	Client/Server Services	Real Time Services																		
Task	SCADA/HMI	Device to Device Communication																		
Key Properties	Not time critical, association between client – server, unicast communication	Time critical, multicast communication																		
Participants	1 client + 1 server	1 Publisher + X Receiver																		
Example	<div><ul style="list-style-type: none">ControlReports<table><tr><th>IEC 61850 SERVICES</th><th>MMS SERVICES</th></tr><tr><td>LogicalDeviceDirectory</td><td>GetNameList</td></tr><tr><td>GetAllDataValues</td><td>Read</td></tr><tr><td>GetDataValues</td><td>Read</td></tr><tr><td>SetDataValues</td><td>Write</td></tr><tr><td>GetDataDirectory</td><td>GetNameList</td></tr><tr><td>GetDataDefinition</td><td>GetVariableAccessAttributes</td></tr><tr><td>GetDataSetValues</td><td>Read</td></tr><tr><td>SetDataSetValues</td><td>Write</td></tr></table><div>.....</div></div>	IEC 61850 SERVICES	MMS SERVICES	LogicalDeviceDirectory	GetNameList	GetAllDataValues	Read	GetDataValues	Read	SetDataValues	Write	GetDataDirectory	GetNameList	GetDataDefinition	GetVariableAccessAttributes	GetDataSetValues	Read	SetDataSetValues	Write	<div><ul style="list-style-type: none">GOOSE (Generic Object Oriented System Events)Sample Value (SV)</div>
IEC 61850 SERVICES	MMS SERVICES																			
LogicalDeviceDirectory	GetNameList																			
GetAllDataValues	Read																			
GetDataValues	Read																			
SetDataValues	Write																			
GetDataDirectory	GetNameList																			
GetDataDefinition	GetVariableAccessAttributes																			
GetDataSetValues	Read																			
SetDataSetValues	Write																			

IEC61850, Ethernet Redundancy and Digital Substation Journey


Generic Object Oriented System Events (GOOSE)



- Standardized horizontal communication
- Replaces hard-wiring between Relays & Controllers
- GOOSE is used to broadcast events between Relays in a substation.
- The GOOSE communication link between the Relays is supervised by sending data cyclically.
- Ethernet technology offers a fast and reliable station bus for transfer of data.

IEC61850, Ethernet Redundancy and Digital Substation Journey

GOOSE performance




- GOOSE speed requirements from IED to IED as defined by the standard Type 1 (fast messages)
 - Type 1A (tripping)
 - Class P2/3: <3 ms (transmission)
 - **Class P1: <10 ms (distribution)**
 - Type 1B (others)
 - Class P2/3: <20 ms
 - Class P1: <100 ms
- Following the IEC 61850 standard means that peer-to-peer signalling is faster than traditional hard-wiring for Type 1A Class P1 or Class P2/3.
- Reduced wiring & faster response times.

IEC61850, Ethernet Redundancy and Digital Substation Journey


Reverse Blocking protection: GOOSE vs. conventional wiring

Conventional



Delay setting with inst. O/C protection (conventional approach)	
Safety marginal, e.g. delay in operation due to CT saturation.	20...40 ms
O/C protection start delay + output relay's delay	<40 ms
Start delay with receiving relay + retarding time for the blocking signal *)	<40 ms
ALL TOGETHER	100...120 ms

GOOSE




Delay setting with inst. O/C protection (REF615 GOOSE approach)	
Safety marginal, e.g. delay in operation due to CT saturation.	20...40 ms
O/C protection start delay	20 ms
Retardation time of inst. O/C stage blocking	5 ms
GOOSE delay (Type 1A, Class P1)	<10 ms
ALL TOGETHER	55...75 ms

IEC61850, Ethernet Redundancy and Digital Substation Journey

Sample Values

Sample Value Concept




Sample Value Based Merging Unit/Relay

- **Merging Unit:** The interface of the instrument transformers (both conventional & non-conventional) with relays is through a device called Merging Unit (MU) or relays with MU capabilities for Centralized Protection.
- MU is defined in IEC 61850-9-1 as interface unit that accepts current transformer (CT)/voltage transformer (VT) & binary inputs (BI) & produces multiple time synchronized serial unidirectional multi-drop digital point to point outputs to provide data communication via the logical interfaces.
- IEC 61850-9-2LE or IEC 61869-9 defines a sampling frequency of 4 kHz (in 50 Hz networks) & 4.8 kHz (in 60 Hz networks) for raw measurement values to be sent to subscribers (CPC unit or protection relay in some cases) to emulate the signals from instrument transformers or sensors. The relays or CPC unit will then be able to run its protection & measurement functions without having to make any adaptations.

IEC61850, Ethernet Redundancy and Digital Substation Journey

Specific Communication Mapping




- The abstract data & object models of IEC 61850 define a standardized method of describing power system devices that enables all Relays to present data using identical structures that are directly related to their power system function.
- The Abstract Communication Service Interface (ACSI) models of IEC 61850 define a set of services & the responses to those services that enables all IEDs to behave in an identical manner from the network behavior perspective.
- In addition to the mapping to the application layer, Part 8.1 defines profiles for the “other” layers of the communication stack that are dependent on the service provided. The Sampled Values & GOOSE applications map directly into the Ethernet data frame thereby eliminating processing of any middle layers; the MMS Connection Oriented layer can operate over TCP/IP or ISO; all data maps onto an Ethernet data frame using either the data type “Ethertype” in the case of Sampled Values, GOOSE, TimeSync, & TCP/IP or “802.3” data type for the ISO & GSSE messages.

IEC 61850

Technical Benefits


Process Bus Example



Raw phase measurements sent with 4kHz sampling rate

IEC61850, Ethernet Redundancy and Digital Substation Journey


Engineering – SCL Concept



- IEC 61850-6 specifies a Substation Configuration Language (SCL) that is based on the eXtensible Markup Language (XML) to describe the configuration of IEC 61850 based systems.
- The various SCL files include system specification description (SSD), IED capability description (ICD), substation configuration description (SCD), & configured IED description (CID) files. All these files are constructed in the same methods & format but have different scopes depending on the need.
- SCL enables the sharing of IED configuration among users & suppliers to reduce or eliminate inconsistencies & misunderstandings in system configuration & system requirements. Users can provide their own SCL files to ensure that IEDs are delivered to them properly configured.

IEC61850, Ethernet Redundancy and Digital Substation Journey

Importance of Conformance Testing

**IEC 61850 Certificate Level A¹**
No. 74105701-OPE/INC 15-1136

Issued to:
ABB Oy
Medium Voltage Products
Muutitie 2
FI-65101 Vaasa
Finland

For the server product:
REF615 Protection and Control Relay
Product version: 5.0 FP1
Software version: 5.1
Hardware version: G

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.0 with product's protocol, model and technical issue implementation conformance statements and the extra information for testing: "Protocol Implementation Conformance Statement for the IEC 61850 interface in 615 series - Revision H", "IEC 61850 Ed2 Model Implementation Conformance Statement (MICS) for 615 series - Revision B", "TISSUES Implementation Conformance Statement for the IEC61850 Ed2 interface in 615 series - Revision B" and "Protocol Implementation extra Information for Testing (PIXIT) for the IEC 61850 interface in 615 series - Revision L".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):


1 Basic Exchange (20/26)	9a GOOSE Publish (11/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (12/14)
4 Setting Group Selection (4/4)	12a Direct Control (6/18)
4+ Setting Group Definition (11/13)	12d Enhanced SBO Control (14/28)
5 Unbuffered Reporting (16/20)	13 Time Synchronization (6/7)
6 Buffered Reporting (23/29)	14 File Transfer (7/8)


This certificate includes a summary of the test results as carried out at ABB Oy in Finland with UniCA 61850 Client simulator 4.29.03 with test suite Ed2 3.29.02 and UniCA 61850 Analyzer 5.28.03. This document has been issued for information purposes only, and the original paper copy of the DNV GL report No. 74105701-OPE/INC 15-1135 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by ABB Oy. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, April 23, 2015

**M. Adriaenssen**
Head of Department
Operational Excellence

Issued by:

DNV GL
DNV KEMA is now DNV GL

**R. Schimmel**
Certification Manager


¹ Level A - Independent test lab with certified ISO 9001 Quality System
² TPCL - Test procedures change list

Copyright © KEMA/Nederland B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

- **Conformance Testing:** For the success of multi-vendor substation automation system with IEC 61850 protocol, an effective process & set of procedures for verifying IEC 61850 products is needed. IEC 61850-10 describes the technical & documentation requirements for product conformance testing to the standard. Conformance testing of IEC 61850 based devices will provide the verification that the documentation, communication & data model specifications have been implemented correctly according to the IEC 61850 standard. The objective of conformance testing is to give confidence to users before actual system integration that certified devices from different manufacturers will inter-operate flawlessly under normal, stress & error situations. Conformance testing significantly reduces the risk of costly & time-consuming problems occurring during system integration & operation.

IEC61850, Ethernet Redundancy and Digital Substation Journey

Beyond conformance testing (Interoperability)




- Interoperability testing is not in the scope of the IEC standard or UCAIug accredited test labs & testing procedures. Standard conforming products from different suppliers or different products from the same supplier need not fulfill the same functional scope of supply.
- The interoperability test is testing the dynamic & inter-operable interaction of at least two IEDs in a Substation Automation System covering all potential configurations as far as possible. Also, the performance of services including delays caused by communication equipment like switches is verified. The interoperability testing in customer projects consists of project related tests, based on the customer specification for an ordered Substation Automation System.
- It is always recommended to carry out interoperability test before deciding the IEDs for the project to avoid any potential risk between specification or requirement against actual substation automation functionality. **Always remember, Protection Relays can have conformance with IEC 61850 standards however still not be inter-operable in a system.**

IEC61850, Ethernet Redundancy and Digital Substation Journey

Ethernet Redundancy

IEC61850, Ethernet Redundancy and Digital Substation Journey

Ethernet Redundancy



- High speed & highly reliable substation communication network is critical in any substation. IEC 61850-90-4: Communication networks & systems for power utility automation – Part 90-4: Network engineering guidelines can be handy to design such network.
- Substations operate round the clock & hardly shut down for maintenance, protection system involved must isolate the primary plant in the faulted zone immediately. Under such dynamic conditions, file & data transfer over Ethernet in a digital protection scheme, if experienced a mal-function, could spell disaster for the protection scheme.
- Utilities & industries have been striving to have reliable communications between substation assets like protection relays & substation automation systems (SAS) that can monitor, record & clear system disturbances within the least possible time.
- A usual requirement is the avoidance of any single point of failure, which implies the introduction of redundancy.

IEC61850, Ethernet Redundancy and Digital Substation Journey

Ethernet Redundancy


IEC 61850-5, Clause 11.4.4, Table 7

Communicating partners	Application recovery delay	Recovery delay of communication
SCADA to IED, client-server	800 ms	400 ms
IED to IED interlocking	12 ms	4 ms
IED to IED, reverse blocking		
Protection trip excluding Bus Bar protection	8 ms	4 ms
Bus Bar protection	< 1 ms	bumpless
Sampled values	Less than some few consecutive samples	bumpless

- A key parameter for redundancy network designed is how long a substation application tolerates an interruption of the communication due to recovery from a failure without consequences on the substation.
- IEC 61850-5 specifies in particular the different requirements on recovery time between station bus & process bus.
- If an IEC 61850 frame is not received in a timely manner, it loses its usefulness; & being late could be worse than being lost.
- A network should be designed from the start with full redundancy to utilize the full communication services as defined by IEC 61850.
- Numerous protocols provide partial or full network redundancy; the concepts are described in IEC 62439-1. However, we will focus on RSTP (Rapid Spanning Tree Protocol), PRP (Parallel Redundancy Protocol) & HSR (High-availability Seamless Redundancy) for IEC 61850 based substation.


IEC61850, Ethernet Redundancy and Digital Substation Journey

Ethernet self-healing ring topology



- RSTP is primarily intended for automatic LAN configuration & loop prevention, it provides redundancy against link & bridge failures.
- Although RSTP does not provide seamless recovery (0 msec loss of communication) however carefully engineered RSTP network with restrictions specified in IEC 62439-1:2010 can recover fast enough (as per IEC 61850-90-4 standard, RSTP recovery time in best case scenario will be approx. 200 msec for 40 nodes) for most applications that use the station bus or non-critical IEC 61850 traffic.
- However, RSTP should not be used for traffic like time critical GOOSE messages (Type 1A, Class P1/P2) & Sample Values since as per IEC 61850-5 recovery time for such IEC 61850 services are either close to 4 msec or bumpless.
- IEC 62439 specifies in part 3 two seamless systems: PRP & HSR. The PRP & HSR protocols provide seamless recovery or zero communication frame loss & therefore can be used for demanding applications like time critical GOOSE messages and/or Sample Values.


HSR - communication redundancy



- **HSR (High-availability Seamless Redundancy) IEC 62439-3 Clause 5** If the ring is broken, messages will still arrive over the intact path. A broken ring is easily detected since duplicate messages are no longer received.
- **Normal condition** Message from IED is sent via both links (“A” & “B”) to the SCADA via HSR ring.

IEC61850, Ethernet Redundancy and Digital Substation Journey


HSR - communication redundancy



- **HSR (High-availability Seamless Redundancy) IEC 62439-3 Clause 5** If the ring is broken, messages will still arrive over the intact path. A broken ring is easily detected since duplicate messages are no longer received.
- **Normal condition** Message from IED is sent via both links ("A" & "B") to the SCADA via HSR ring.
- **Operation under failure condition** Failure recognized in HSR ring ("A" link). Message is received by SCADA via healthy part of ring ("B" link)


IEC61850, Ethernet Redundancy and Digital Substation Journey

PRP- communication redundancy



- **PRP (Parallel Redundancy Protocol) IEC 62439-3 Clause 4**
- The communication network is fully duplicated.
- If only one packet is received, the receiver knows the other path is broken.
- **Normal condition** Message is received in COM600 via both parallel links (LAN “A” & LAN “B”)

PRP- communication redundancy




- **PRP (Parallel Redundancy Protocol) IEC 62439-3 Clause 4**
- The communication network is fully duplicated.
- If only one packet is received, the receiver knows the other path is broken.
- **Operation under failure condition**
- Failure recognized in PRP network (LAN “A”)
- Message is received in COM600 via healthy link (LAN “B”)

IEC61850, Ethernet Redundancy and Digital Substation Journey

Digital Substation Journey

Centralized protection, measurement and control for digital substations

Step by Step from Convention to Digitalization



1. Electromechanical and solid-state relays.
2. Adds communications with an RTU or data concentrator.
3. Communication protocols by DNP3, Modbus or IEC61850, more recently, it's getting common to see peer-to-peer communications and customized control logic using GOOSE. The redundant communication scheme HSR/PRP has gradually been standardized.
4. IEC 61850-9-2 to transfer the digitized Sampled Values (SMV) from the merging unit directly to the IED.
5. Use optical fiber communication to transfer digitized Sampled Values (SMV) from the Intelligent Merging Unit (IMU) to the CPC, as well as GOOSE messages from the CPC to the IMU, and MMS messages from the IMU to the CPC.

ABB Electrification – Digital Substation journey

Step 1

Bay level IED's

1. Select IEC61850 PRP/HSR communication
2. Select IEC61850-9-2LE/process bus compatible devices

Compatible devices in ABB portfolio


- **SMU615 (merging unit)**
- **REx615, REx620, REX640 (IEDs)**



Step 2

System, substation level

1. Deploy IEC61850 managed switches, for PRP/HSR redundant communication
2. Deploy time synchronization
IEEE1588v2 GPS master



Step 3

Centralized protection

1. Deploy SSC600 box, and select the protection packages needed (line/cable/ transformer/motor, ...)
2. Local HMI/Centralized disturbances/IEC104 gateway included in BASIC package
3. Upgrade the substation at anytime by software upgrade to Line distance, Low impedance busbar differential, and many more, Load shedding, ...



Smart substation control SSC600

Digital Substations “box”




Market needs

- Future-proof solution for Substation and Protection and Control
- IEC61850 GOOSE/sampled values-based architecture
- Applications flexibility and upgradability, 2.5x faster application cycles
- Simplify architectures to reduce maintenance and operations costs
- Flexible concept, with SSC600 available as «substation upgrade»
- Easy «do it yourself» configuration through ABB PST tool
- Enables remote services, configurations, upgrades and support
- Remote asset and fleet management, settings and configurations backup
- Upcoming system and settings optimization features, neural network

Solution

Smart Substation Control SSC600

- Configuration + settings backup
- Local HMI + including virtual buttons / logics
- Backup protection schemes
- Centralized disturbances recorder
- Distance + extended protection functions
- Centralized engineering
- Feature pack 1: Low impedance busbar differential
- Feature pack 2: IEC 104 slave




Centralized protection, measurement and control for digital substations


Sampled Values – Intensive sampling rate

Majority of Relays utilize 32 samples/cycle (1.6kHz), while only some might require 192 s/c (9.6 kHz)

Relay Internal Hardware
Analog/Digital conversion
Raw sampling
1.2Mhz filtered
to 9.6 kHz



Physical Current/Voltage inputs
(Conventional or Sensors)



Application packages

SSC600/SSC600SW Feature Pack 4, up to 30 61850-9-2LE streams (30 x 4 currents/4 voltages)

Base functionality (always included)		Optional packages & functions		
Substation management	Basic protection functions	Cable/line application (5-10-15-20-30 bays)	Transformer protection (0-2-4 bays)	Bay-level applications (for selected and available streams)
Functionalities	Basic protection			
Web HMI with station SLD	Current protection_50/51	Directional EF_67N	Thermal overload_49/T/G/C	Tap-changer indication and control with voltage regulator
Breaker monitoring	Earth-fault_50N/51N	3-ph. direct. reverse power_32R/32O	Transformer differential_87T	Distance protection_21P, 21N
Measurements_3I/3V/In/Vn/f/...	3-phase undervoltage_27	Phase-discontinuity_46PD	Low-impedance REF_87NL	Power quality <ul style="list-style-type: none">Current total demand and harmonic distortion (TDD and THD)Voltage total harmonic distortion (THD)Voltage variationVoltage unbalance
Fault recorder	3-phase overvoltage_59	Thermal protection_49F	3-phase underimpedance_21G	
Disturb. recorder (centralized)	Residual overvoltage_59N	Autoreclosing_79	Tap-changer position indication_84M	
IEC61850-9-2LE SMV receiving	Neg.seq. overvoltage_47O-	Synchrocheck_25		
IEC61850 GOOSE/R-GOOSE/MMS	Pos.seq. undervoltage_47U+	Directional OC_67P	Motor application (0-5-10-15-20-30 bays)	Multi-bay level applications (up to 30 bays)
Advanced logics	Negative-sequence OC_46	Advanced cable/line application (5-10-15-20-30 bays)	Thermal overload_49M	Load-shedding and restoration across 4 bus sections_81LSH
Alarms	Frequency protection_81	MF-admittance EF_67NYH	Neg.seq. OC for machines_46M	Low imp. busbar differential_87BL/87B
Events and audit log	Fuse failure supervision_VCM,60	Admittance EF_21YN	Loss of load supervision_37	Arc protection_50L/50NL
PRP redundant communication	Three-phase inrush detect._68HB	Intermittent EF_67NIEF	Motor load jam_51LR	
Redundant power supply	Circuit-breaker failure_51BF	Wattmetric EF_32N	Motor startup supervision_49/66/48/51LR	Shunt capacitor protection
Time synch. with IEEE 1588 v2	Master trip_94/86	Low-voltage ride-through protection_27RT	Phase reversal 46R	3-ph overload_51,37,86C
IEC 60870-5-104	Switch onto fault_SOTF	Fault locator_21FL	Emergency startup_ESTART	Current unbalance_60N
Anomaly detector ANOGAPC	Load blinder_21LB	Direct. react. power underv._32Q/27		3-ph current unbalance_60P
				Cap. bank switching resonance_55ITHD

SSC600 applications and features, available in 3 variants

SSC600 FP4 workstation
(including 61850-3 server)

SSC600 SW (FP4)
(software VM for Linux KVM)

SSC600 SW (FP4)
(software VM for Vmware 7.x)



Centralized protection, measurement and control for digital substations


Protection - Simplified Low Imp Busbar Differential protection

Customer need

- Cost-efficient protection for busbar
- Different choices for implementation of busbar protection
- Busbar protection without additional hardware

Solution

- Arc flash protection
 - MUs sense the light whereas CPC has the logic for selective tripping
 - Easy-to-manage and engineer system with multiple sensors
- Busbar differential protection
 - Based on the low-impedance differential principle
 - No need for extra equipment in addition to CPC and IMUs/MUs
 - Up to 20 bays
 - 2 protection zones and a check zone
 - For single and double busbars



Centralized protection, measurement and control for digital substations


Main functionalities

Configuration status

Detailed view of the protection and control application

Enables an easy way to find logical errors in the installation

Complete list of all activated protection functions



Centralized protection, measurement and control for digital substations

Main functionalities

Settings management

Settings of the complete substation

Compare settings between different protection stages

Easy to ensure protection selectivity when all protection functions are in the same view

Home / Organizations / PVC / Substations / STA_01 / Voltage levels / VOL_12 / Bays / BAY_121 / Applications / Protection / Settings / Parameter value

Search

Application informationFunctionsSettings

STA_01VOL_12BAY_121ControlMeasurementsProtectionBAY_122BAY_123BAY_124BAY_125BAY_126BAY_127BAY_128BAY_129BAY_130BAY_131BAY_132BAY_133BAY_134BAY_135BAY_136BAY_137

Settings tool

This application configuration is not compatible with MVAM settings view. The following functions have more than one instance per bay with same user defined name: DPHLPDOC,DQPTUV,DEFLPDEF. They are excluded from the view.

Access category: basicSetting group: 1

ARCASARC

	Common	BAY_1211	BAY_1222	BAY_1233	BAY_1244	BAY_1255	BAY_1266	BAY_1277	BAY_1288	BAY_1299	BAY_13010
Operation	on										
Ground start value (xin)	0.2										
Operation mode	Light+current										
Phase start value (xin)	Select value	2.5	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2

CCBRBRF


Centralized protection, measurement and control for digital substations

Main functionalities

Fault analysis

Monitor all substation level events

Detailed analysis of faults with disturbance recordings



Centralized protection, measurement and control for digital substations

Main functionalities

Asset management

- View all version information of installed devices
- Status of the whole fleet in one view

ABB

MVAM

Configurations

Events

More

0

EN

Home / Organizations / Caruna / Assets / Products

ApplicationsProductsLicenses

Products

Search products..

PLACE	PRODUCT	VERSION	IEC EDITION	SERIAL	ORDER CODE	LICENSE	FIRMWARE	UPDATE AVAILABLE	UPDATE FIRMWARE
NOO	SSC600	G	1		SBFJAEAGNBA1BEC21G		1.0.0-a9	No	<input checked="" type="checkbox"/> Selected for update
NOO2	SSC600	G	1	1VHB51010002	SBADDNBDCBA1AGC21G	Download	1.0.0-rc7	No	<input checked="" type="checkbox"/> Selected for update

Select firmware:CancelWrite

IEC61850, Ethernet Redundancy and Digital Substation Journey

Summary

IEC61850, Ethernet Redundancy and Digital Substation Journey

Summary

- Enables **rapid data exchange** via GOOSE, optimizing LAN use.
- **Reduces wiring costs** by eliminating the need for separate relay links.
- Supports **Sample Values** for flexible analog signal transfer.
- **Conformance testing** verifies standard compliance in devices.
- Promotes **interoperable, future-proof** substation automation.
- **Redundancy strategy** selection is critical from the start.

IEC 61850 and Ethernet Redundancy

Questions & Answers

Harlem Tsai

Global Product Marketing Manager – South Asia Region

Digital Substation Products & Digital Systems

Electrification, Distribution Solutions


ABB Oy

Vaasa, Finland

Email: Harlem.Tsai@fi.abb.com

Mobile: +358 503358820

<http://new.abb.com/medium-voltage/distribution-automation>



ABB