



Certificate of Compliance

Certificate: 2310045

Master Contract: 169702

Project: 2310045

Date Issued: October 15, 2010

Issued to: Cable Management Products Ltd.

Station Rd
Coleshill, Birmingham B46 1HT
United Kingdom
Attention: Phillip Winship

The products listed below are eligible to bear the CSA Mark shown



Andrea Holbeche

Issued by: Andrea Holbeche

PRODUCTS

CLASS 4418 03 - CONDUIT FITTINGS - Fittings - For Hazardous Locations

Class I Division 1 Groups B, C and D; Class II Division 1 Groups E, F and G; Ambient temperature range – 60 °C to + 130 °C

HA****U and HA****E Range of Compound Conduit Stopping boxes for use with rigid conduit and other threaded fittings. Brass or stainless steel, sizes 3/8" NPT, 1/2" NPT, 3/4" NPT, 1" NPT, 1 1/4" NPT, 1 1/2" NPT, 2" NPT

Class I Division 2 Groups A, B, C and D; Class II Division 1 Groups E, F and G; Ambient temperature range – 60 °C to + 130 °C

HA****G1, Conduit Stopping boxes for use with flexible, liquid tight conduit. Brass or stainless steel, sizes 3/8" NPT, 1/2" NPT, 3/4" NPT, 1" NPT, 1 1/4" NPT, 1 1/2" NPT, 2" NPT



Certificate: 2310045

Master Contract: 169702

Project: 2310045

Date Issued: October 15, 2010

Note: See Descriptive Report for complete nomenclature breakdown.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No.0 - M91 General Requirements – Canadian Electrical Code Part II

CAN/CSA-C22.2 No.18.3-04 – Conduit, Tubing, and Cable Fittings

C22.2 No.25-M1966 – Enclosures for Use in Class II, Groups E, F and G Hazardous Locations

C22.2 No.30 - M1986 – Explosion-proof Enclosures for Use in Class I Hazardous Locations

MARKINGS

The equipment is marked with legible, permanent engraving.

CSA logo

Manufacturer's name: Cable Management Products Ltd

Hazardous locations designation, as applicable - HA****U and HA****E: Class I Division 1 Groups B, C and D, Class II Division 1 Groups E, F and G, SL; HA****G1: Class I Division 2 Groups A, B, C and D, Class II Division 1 Groups E, F and G, SL.

Ambient temperature range: -60°C to +130°C

Serial number or Year of manufacture

Note - Jurisdictions in Canada may require these markings to also be provided in French language. It is the responsibility of the manufacturer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities. It is the responsibility of the manufacturer to determine this requirement and have bilingual wording added to the "Markings".