

IEC

IECEE  
CB  
SCHEME

Ref. Certif. No.

CN48615

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

### CB TEST CERTIFICATE

Product

Contacteur

Name and address of the applicant

ABB Stotz-Kontakt GmbH  
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the manufacturer

ABB Stotz-Kontakt GmbH  
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the factory

ABB Stotz-Kontakt GmbH  
Eppelheimer Strasse 82 69123 Heidelberg Germany

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ESB40-xxN, ESB63-xxN, EN40-xxN;

Additional information (if necessary may also be reported on page 2)

IEC 60947-4-1:2018

A sample of the product was tested and found to be in conformity with

00901-CB2018CQC-083984

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

#### CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>



Date: Oct.24,2019

Signature:

Lu Mei

CB 0054614

ESB40-xxN, ESB63-xxN, EN40-xxN

Ui: 500V;

Uimp: 6kV;

Ith: 63A(ESB63-xxN), 40A(ESB40-xxN, EN40-xxN);

ESB40-xxN, EN40-xxN: AC-1: Ue/Ie: AC400V/40A(NO), AC400V/30A(NC);

ESB63-xxN : AC-1: Ue/Ie: AC400V/63A(NO), AC400V/30A(NC);

ESB40-xxN, EN40-xxN: AC-3/AC-3e: Ue/Ie: AC400V/22A(NO);

ESB63-xxN : AC-3/AC-3e: Ue/Ie: AC400V/30A(NO);

ESB40-xxN, EN40-xxN: DC-1: Ue/Ie: DC220V/1.0A(NO);

DC-3: Ue/Ie: DC220V/0.3A(NO);

ESB63-xxN: DC-1: Ue/Ie: DC220V/1.1A(NO);

DC-3: Ue/Ie: DC220V/0.3A(NO);

Us: 12V, 24V, 42V, 48V, 110V, 230V, 240V, 400V, 415V 40...450Hz/DC; DC24V;

IP20;

4P;

Auxiliary contact:EH04-11N,EH04-20N


1NO1NC, 2NO;

Ith: 6A;

AC-15:Ue/Ie:120V/6A(NO/NC),240V/4A(NO/NC),415V/1A(NC)/3A(NO),500V/1A(NC)/2A(NO)

Additional information (if necessary)

Date: Oct.24,2019

Signature: 

Lu Mei



Ref. Certif. No.

CN40984

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product  
Produit

Electromechanical contactors for household and similar purposes

Name and address of the applicant  
Nom et adresse du demandeurABB STOTZ-KONTAKT GmbH  
Eppelheimer Strasse 82 69123 Heidelberg GermanyName and address of the manufacturer  
Nom et adresse du fabricantABB STOTZ-KONTAKT GmbH  
Eppelheimer Strasse 82 69123 Heidelberg GermanyName and address of the factory  
Nome et adresse de l'usineABB STOTZ-KONTAKT GmbH  
Eppelheimer Strasse 82 69123 Heidelberg GermanyNote: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> pageRatings and principal characteristics  
Valeurs nominales et caractéristiques principalesUi: 500V; Ith: 63A (ESB63-xxN), 40A (ESB40-xxN, EN40-xxN); ESB40-xxN,  
EN40-xxN: AC-7a: Ue/Ie: AC400V/40A(NO), AC400V/30A(NC);  
ESB63-xxN: AC-7a: Ue/Ie: AC400V/63A(NO), AC400V/30A(NC);  
ESB40-xxN, EN40-xxN: AC-7b: Ue/Ie: AC400V/22A(NO); ESB63-xxN :  
AC-7b: Ue/Ie: AC400V/30A(NO); Us: 12V, 24V, 42V, 48V, 110V, 230V, 240V,  
400V, 415V 50/60Hz/DC; DC24V IP20; 4PTrademark (if any)  
Marque de fabrique (si elle existe)

ABB

Model / Type Ref.  
Ref. De type

ESB40-xxN, ESB63-xxN, EN40-xxN

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)**PUBLICATION****EDITION**A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 61095 (2nd Edition):2009

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

00901-CB2017CQC-075161

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: Aug.15,2017

Signature:

Wang Kejiao